

Systemfamilie PLM 700

Modulares CAN I/O-System

SIM.730.28

Gateway BACnet/IP

BACnet
Protocol Implementation
Conformance Statement
(PICS)

Copyright © SABO Elektronik GmbH 2013

Weitergabe oder Vervielfältigung dieses Dokuments ohne ausdrückliche schriftliche Genehmigung der SABO Elektronik GmbH nicht gestattet. Alle Rechte vorbehalten.

Haftungsausschluss

Der Inhalt des Dokuments wurde auf Übereinstimmung mit der beschriebenen Hard- und Software geprüft. Dennoch können Abweichungen nicht ausgeschlossen werden, so dass wir für die vollständige Übereinstimmung keine Gewähr übernehmen. Die Angaben in dieser Druckschrift werden regelmäßig überprüft; notwendige Korrekturen sind in den nachfolgenden Auflagen enthalten. Verbesserungsvorschläge sind jederzeit willkommen.

SABO Elektronik GmbH
Lohbachstr. 14
58239 Schwerte
Tel. 02304 / 97102 - 0
Fax 02304 / 97102 - 22

E-Mail info@sabo.de
Internet www.sabo.de

Letzte Aktualisierung: 28. Mai. 2014

BACnet Protocol Implementation Conformance Statement

General Information:

Date:	10.03.2012
Vendor Name:	SABO Elektronik GmbH
Product Name:	SIM.730.28
Product Model Number:	1.0
Application Software Version:	Sep 24 2013
BACnet Protocol Version:	1
BACnet Protocol Revision:	7

Product Description:

The SABO SIM.730.28 gateway provides access to BACnet networks acting as a BACnet server or a BACnet client.

BACnet Standardized Device Profile (Annex L):

- BACnet Operator Workstation (B-OWS)
- BACnet Building Controller (B-BC)
- BACnet Advanced Application Controller (B-AAC)
- BACnet Application Specific Controller (B-ASC)
- BACnet Smart Sensor (B-SS)
- BACnet Smart Actuator (B-SA)

List of all BACnet Interoperability Building Blocks Supported (Annex K):

1. Data-Sharing BIBBs

Data Sharing Read-Property-A	DS-RP-A
Data Sharing Read-Property-B	DS-RP-B
Data Sharing Read-Property-Multiple-A	DS-RPM-A
Data Sharing Read-Property-Multiple-B	DS-RPM-B
Data Sharing Write-Property-A	DS-WP-A
Data Sharing Write-Property-B	DS-WP-B
Data Sharing Write-Property-Multiple-A	DS-WPM-A
Data Sharing Write-Property-Multiple-B	DS-WPM-B
Data Sharing COV-A	DS-COV-A
Data Sharing COV-B	DS-COV-B
Data Sharing COVP-B	DS-COVP-B

2. Alarm and Event BIBBs

Alarm and Event-Notification-Internal B	AE-N-I-B
Alarm and Event-Notification-External B	AE-N-E-B
Alarm and Event-ACK-B	AE-ACK-B
Alarm and Event-Alarm Summary-B	AE-ASUM-B
Alarm and Event-Enrollment Summary-B	AE-ESUM-B
Alarm and Event-Event Information-B	AE-INFO-B
Alarm and Event-LifeSafety-B	AE-LS-B

3. Scheduling BIBBs

Scheduling-Internal-B	SCHED-I-B
Scheduling-External-B	SCHED-E-B

4. Trending BIBBs

No Trending BIBBs supported.

5. Device Management BIBBs

Device Management-Dynamic Device Binding-B	DM-DDB-B
Device Management-Dynamic Object Binding-B	DM-DOB-B
Device Management-DeviceCommunicationControl-B	DM-DCC-B
Device Management-TimeSynchronization-A	DM-TS-A
Device Management-TimeSynchronization-B	DM-TS-B
Device Management-UTCTimeSynchronization-A	DM-UTC-A
Device Management-UTCTimeSynchronization-B	DM-UTC-B
Device Management-ReinitializeDevice-B	DM-RD-B
Device Management-List Manipulation-B	DM-LM-B

6. Network Management BIBBs

No Network Management BIBBs supported.

Segmentation Capability:

- Segmented requests supported, Window Size: 16
 - Segmented responses supported, Window Size: 16
- (Changeable by driver configuration)

Data Link Layer Options:

- BACnet IP, (Annex J)
- BACnet IP, (Annex J), Foreign Device

- ISO 8802-3, Ethernet (Clause 7)
- ANSI/ATA 878.1, 2.5 Mb. ARCNET (Clause 8)
- ANSI/ATA 878.1, RS-485 ARCNET (Clause 8)
- MS/TP master (Clause 9)
- MS/TP slave (Clause 9)
- Point-To-Point, EIA 232 (Clause 10)
- Point-To-Point, modem, (Clause 10)
- LonTalk, (Clause 11)
- Other: _____

Device Address Binding:

Is static device binding supported? (This is currently necessary for two-way communication with MS/TP slaves and certain other devices.)

- Yes
- No

Networking Options:

Router, Clause 6

(Yes, if multiple datalayers are activated. Changeable by driver configuration)

- Annex H, BACnet Tunneling Router over IP
- BACnet/IP Broadcast Management Device (BBMD)
- Does the BBMD support registrations by Foreign Devices?
Number of FD-Entries: 50 (configurable)

Character Sets Supported:

Indicating support for multiple character sets does not imply that they can all be supported simultaneously.

- ANSI X3.4
- IBM□/Microsoft□ DBCS
- ISO 8859-1
- ISO 10646 (UCS-2)
- ISO 10646 (UCS-4)
- JIS C 6226

Non-BACnet equipment/network(s) that the gateway supports:

This BACnet gateway provides interfaces for MODBUS TCP and MODBUS RTU.

Standard Object Types Supported:

The supported object-types are:

Analog Input	(0)
Analog Output	(1)
Analog Value	(2)
Binary Input	(3)
Binary Output	(4)
Binary Value	(5)
Command	(7)
Device	(8)
Event Enrollment	(9)
Multistate Input	(13)
Multistate Output	(14)
Notification Class	(15)
Schedule	(17)
Multistate Value	(19)

Creation and Deletion of objects is not supported.

Analog Input

Property Identifier	Property Datatype	Conformance Code	UGW-compact
Object_Identifier	BACnetObjectIdentifier	R	R
Object_Name	CharacterString	R	R
Object_Type	BACnetObjectType	R	R
Present_Value	REAL	R ₁	R ₁ /W
Description	CharacterString	O	-/R/W
Device_Type	CharacterString	O	-/R/W
Status_Flags	BACnetStatusFlags	R	R
Event_State	BACnetEventState	R	R
Reliability	BACnetReliability	O	R/W
Out_Of_Service	BOOLEAN	R	R/W
Update_Interval	Unsigned	O	-/R/W
Units	BACnetEngineeringUnits	R	R/W
Min_Pres_Value	REAL	O	-/R/W
Max_Pres_Value	REAL	O	-/R/W
Resolution	REAL	O	-/R/W
COV_Increment	REAL	O ₂	-/R/W
Time_Delay	Unsigned	O ₃	-/R/W
Notification_Class	Unsigned	O ₃	-/R/W
High_Limit	REAL	O ₃	-/R/W
Low_Limit	REAL	O ₃	-/R/W
Deadband	REAL	O ₃	-/R/W
Limit_Enable	BACnetLimitEnable	O ₃	-/R/W
Event_Enable	BACnetEventTransitionBits	O ₃	-/R/W
Acked_Transitions	BACnetEventTransitionBits	O ₃	-/R
Notify_Type	BACnetNotifyType	O ₃	-/R/W
Event_Time_Stamps	BACnetARRAY[3] of BACnetTimeStamp	O ₃	-/R
Profile_Name	CharacterString	O	-/R/W

¹ This property is required to be writable when Out_Of_Service is TRUE.

² This property is required if the object supports COV reporting.

³ These properties are required if the object supports intrinsic reporting.

Each property can be set into its state (not present / required / writeable) according to the UGW compact code.

Analog Output

Property Identifier	Property Datatype	Conformance Code	UGW-compact
Object_Identifier	BACnetObjectIdentifier	R	R
Object_Name	CharacterString	R	R
Object_Type	BACnetObjectType	R	R
Present_Value	REAL	W	W
Description	CharacterString	O	-/R/W
Device_Type	CharacterString	O	-/R/W
Status_Flags	BACnetStatusFlags	R	R
Event_State	BACnetEventState	R	R
Reliability	BACnetReliability	O	-/R/W
Out_Of_Service	BOOLEAN	R	R/W
Units	BACnetEngineeringUnits	R	R/W
Min_Pres_Value	REAL	O	-/R/W
Max_Pres_Value	REAL	O	-/R/W
Resolution	REAL	O	-/R/W
Priority_Array	BACnetPriorityArray	R	R
Relinquish_Default	REAL	R	R/W
COV_Increment	REAL	O ₁	-/R/W
Time_Delay	Unsigned	O ₂	-/R/W
Notification_Class	Unsigned	O ₂	-/R/W
High_Limit	REAL	O ₂	-/R/W
Low_Limit	REAL	O ₂	-/R/W
Deadband	REAL	O ₂	-/R/W
Limit_Enable	BACnetLimitEnable	O ₂	-/R/W
Event_Enable	BACnetEventTransitionBits	O ₂	-/R/W
Acked_Transitions	BACnetEventTransitionBits	O ₂	-/R
Notify_Type	BACnetNotifyType	O ₂	-/R/W
Event_Time_Stamps	BACnetARRAY[3] of BACnetTimeStamp	O ₂	-/R
Profile_Name	CharacterString	O	-/R/W

¹ This property is required if the object supports COV reporting.

² These properties are required if the object supports intrinsic reporting.

Each property can be set into its state (not present / required / writeable) according to the UGW compact code.

Analog Value

Property Identifier	Property Datatype	Conformance Code	UGW-compact
Object_Identifier	BACnetObjectIdentifier	R	R
Object_Name	CharacterString	R	R
Object_Type	BACnetObjectType	R	R
Present_Value	REAL	R ₄	R/W
Description	CharacterString	O	-/R/W
Status_Flags	BACnetStatusFlags	R	R
Event_State	BACnetEventState	R	R
Reliability	BACnetReliability	O	-/R/W
Out_Of_Service	BOOLEAN	R	R/W
Units	BACnetEngineeringUnits	R	R/W
Priority_Array	BACnetPriorityArray	O ₁	-/R
Relinquish_Default	REAL	O ₁	-/R/W
COV_Increment	REAL	O ₂	-/R/W
Time_Delay	Unsigned	O ₃	-/R/W
Notification_Class	Unsigned	O ₃	-/R/W
High_Limit	REAL	O ₃	-/R/W
Low_Limit	REAL	O ₃	-/R/W
Deadband	REAL	O ₃	-/R/W
Limit_Enable	BACnetLimitEnable	O ₃	-/R/W
Event_Enable	BACnetEventTransitionBits	O ₃	-/R/W
Acked_Transitions	BACnetEventTransitionBits	O ₃	-/R
Notify_Type	BACnetNotifyType	O ₃	-/R/W
Event_Time_Stamps	BACnetARRAY[3] of BACnetTimeStamp	O ₃	-/R
Profile_Name	CharacterString	O	-/R/W

¹ If Present_Value is commandable, then both of these properties shall be present.

² This property is required if the object supports COV reporting.

³ These properties are required if the object supports intrinsic reporting.

⁴ If Present_Value is commandable, then it is required to be writable. This property is required to be writable when Out_Of_Service is TRUE.

Each property can be set into its state (not present / required / writeable) according to the UGW compact code.

Binary Input

Property Identifier	Property Datatype	Conf. Code	UGW-compact
Object_Identifier	BACnetObjectIdentifier	R	R
Object_Name	CharacterString	R	R
Object_Type	BACnetObjectType	R	R
Present_Value	BACnetBinaryPV	R ₁	R/W
Description	CharacterString	O	-/R/W
Device_Type	CharacterString	O	-/R/W
Status_Flags	BACnetStatusFlags	R	R
Event_State	BACnetEventState	R	R
Reliability	BACnetReliability	O	-/R/W
Out_Of_Service	BOOLEAN	R	R/W
Polarity	BACnetPolarity	R	R/W
Inactive_Text	CharacterString	O ₂	-/R/W
Active_Text	CharacterString	O ₂	-/R/W
Change_Of_State_Time	BACnetDateTime	O ₃	-/R
Change_Of_State_Count	Unsigned	O ₃	-/R
Time_Of_State_Count_Reset	BACnetDateTime	O ₃	-/R
Elapsed_Active_Time	Unsigned32	O ₄	-/R
Time_Of_Active_Time_Reset	BACnetDateTime	O ₄	-/R
Time_Delay	Unsigned	O ₅	-/R/W
Notification_Class	Unsigned	O ₅	-/R/W
Alarm_Value	BACnetBinaryPV	O ₅	-/R/W
Event_Enable	BACnetEventTransitionBits	O ₅	-/R/W
Acked_Transitions	BACnetEventTransitionBits	O ₅	-/R
Notify_Type	BACnetNotifyType	O ₅	-/R/W
Event_Time_Stamps	BACnetARRAY[3] of BACnetTimeStamp	O ₅	-/R
Profile_Name	CharacterString	O	-/R/W

¹ This property is required to be writable when Out_Of_Service is TRUE.

² If one of the optional properties Inactive_Text or Active_Text is present, then both of these properties shall be present.

³ If one of the optional properties Change_Of_State_Time, Change_Of_State_Count, or Time_Of_State_Count_Reset is present, then all of these properties shall be present.

⁴ If one of the optional properties Elapsed_Active_Time or Time_Of_Active_Time_Reset is present, then both of these properties shall be present.

⁵ These properties are required if the object supports intrinsic reporting.

Each property can be set into its state (not present / required / writeable) according to the UGW compact code.

Binary Output

Property Identifier	Property Datatype	Conf. Code	UGW-compact
Object_Identifier	BACnetObjectIdentifier	R	R
Object_Name	CharacterString	R	R
Object_Type	BACnetObjectType	R	R
Present_Value	BACnetBinaryPV	W	R/W
Description	CharacterString	O	-/R/W
Device_Type	CharacterString	O	-/R/W
Status_Flags	BACnetStatusFlags	R	R
Event_State	BACnetEventState	R	R
Reliability	BACnetReliability	O	-/R/W
Out_Of_Service	BOOLEAN	R	R/W
Polarity	BACnetPolarity	R	R/W
Inactive_Text	CharacterString	O ₁	-/R/W
Active_Text	CharacterString	O ₁	-/R/W
Change_Of_State_Time	BACnetDateTime	O ₂	-/R
Change_Of_State_Count	Unsigned	O ₂	-/R
Time_Of_State_Count_Reset	BACnetDateTime	O ₂	-/R
Elapsed_Active_Time	Unsigned32	O ₃	-/R
Time_Of_Active_Time_Reset	BACnetDateTime	O ₃	-/R
Minimum_Off_Time	Unsigned32	O	-/R/W
Minimum_On_Time	Unsigned32	O	-/R/W
Priority_Array	BACnetPriorityArray	R	R
Relinquish_Default	BACnetBinaryPV	R	R/W
Time_Delay	Unsigned	O ₄	-/R/W
Notification_Class	Unsigned	O ₄	-/R/W
Feedback_Value	BACnetBinaryPV	O ₄	-/R/W
Event_Enable	BACnetEventTransitionBits	O ₄	-/R/W
Acked_Transitions	BACnetEventTransitionBits	O ₄	-/R
Notify_Type	BACnetNotifyType	O ₄	-/R/W
Event_Time_Stamps	BACnetARRAY[3] of BACnetTimeStamp	O ₄	-/R
Profile_Name	CharacterString	O	-/R/W

¹ If one of the optional properties Inactive_Text or Active_Text is present, then both of these properties shall be present.

² If one of the optional properties Change_Of_State_Time, Change_Of_State_Count, or Time_Of_State_Count_Reset is present, then all of these properties shall be present.

³ If one of the optional properties Elapsed_Active_Time or Time_Of_Active_Time_Reset is present, then both of these properties shall be present.

⁴ These properties are required if the object supports intrinsic reporting.

Each property can be set into its state (not present / required / writeable) according to the UGW compact code.

Binary Value

Property Identifier	Property Datatype	Conf. Code	UGW-compact
Object_Identifier	BACnetObjectIdentifier	R	R
Object_Name	CharacterString	R	R
Object_Type	BACnetObjectType	R	R
Present_Value	BACnetBinaryPV	R ₁	-/R/W
Description	CharacterString	O	-/R/W
Status_Flags	BACnetStatusFlags	R	R
Event_State	BACnetEventState	R	R
Reliability	BACnetReliability	O	-/R/W
Out_Of_Service	BOOLEAN	R	R/W
Inactive_Text	CharacterString	O ₂	-/R/W
Active_Text	CharacterString	O ₂	-/R/W
Change_Of_State_Time	BACnetDateTime	O ₃	-/R
Change_Of_State_Count	Unsigned32	O ₃	-/R
Time_Of_State_Count_Reset	BACnetDateTime	O ₃	-/R
Elapsed_Active_Time	Unsigned32	O ₄	-/R
Time_Of_Active_Time_Reset	BACnetDateTime	O ₄	-/R
Minimum_Off_Time	Unsigned32	O	-/R/W
Minimum_On_Time	Unsigned32	O	-/R/W
Priority_Array	BACnetPriorityArray	O ₅	-/R/W
Relinquish_Default	BACnetBinaryPV	O ₅	-/R/W
Time_Delay	Unsigned	O ₆	-/R/W
Notification_Class	Unsigned	O ₆	-/R/W
Alarm_Value	BACnetBinaryPV	O ₆	-/R/W
Event_Enable	BACnetEventTransitionBits	O ₆	-/R/W
Acked_Transitions	BACnetEventTransitionBits	O ₆	-/R
Notify_Type	BACnetNotifyType	O ₆	-/R/W
Event_Time_Stamps	BACnetARRAY[3] of BACnetTimeStamp	O ₆	-/R
Profile_Name	CharacterString	O	-/R/W

¹ If Present_Value is commandable, then it is required to be writable. This property is required to be writable when Out_Of_Service is TRUE.

² If one of the optional properties Inactive_Text or Active_Text is present, then both of these properties shall be present.

³ If one of the optional properties Change_Of_State_Time, Change_Of_State_Count, or Time_Of_State_Count_Reset is present, then all of these properties shall be present.

⁴ If one of the optional properties Elapsed_Active_Time or Time_Of_Active_Time_Reset is present, then both of these properties shall be present.

⁵ If Present_Value is commandable, then both of these properties shall be present.

⁶ These properties are required if the object supports intrinsic reporting.

Each property can be set into its state (not present / required / writeable) according to the UGW compact code.

Command

Property Identifier	Property Datatype	Conf. Code	UGW-compact
Object_Identifier	BACnetObjectIdentifier	R	R
Object_Name	CharacterString	R	R
Object_Type	BACnetObjectType	R	R
Description	CharacterString	O	-/R/W
Present_Value	Unsigned	W	W
In_Process	BOOLEAN	R	R
All_Writes_Successful	BOOLEAN	R	R
Action	BACnetARRAY[N] of BACnetActionList	R	R/W
Action_Text	BACnetARRAY[N] of CharacterString	O	-/R/W
Profile_Name	CharacterString	O	-/R/W

Each property can be set into its state (not present / required / writeable) according to the UGW compact code.

Device

Property Identifier	Property Datatype	Conf. Code	UGW-compact
Object_Identifier	BACnetObjectIdentifier	R	R
Object_Name	CharacterString	R	R
Object_Type	BACnetObjectType	R	R
System_Status	BACnetDeviceStatus	R	R
Vendor_Name	CharacterString	R	R
Vendor_Identifier	Unsigned16	R	R
Model_Name	CharacterString	R	R
Firmware_Revision	CharacterString	R	R
Application_Software_Version	CharacterString	R	R
Location	CharacterString	O	-/R
Description	CharacterString	O	-/R
Protocol_Version	Unsigned	R	R
Protocol_Revision	Unsigned	R	R
Protocol_Services_Supported	BACnetServicesSupported	R	R
Protocol_Object_Types_Supported	BACnetObjectTypesSupported	R	R
Object_List	BACnetARRAY[N]of BACnetObjectIdentifier	R	R
Structured_Object_List	BACnetARRAY[N]of BACnetObjectIdentifier	O	-
Max_APDU_Length_Accepted	Unsigned	R	R
Segmentation_Supported	BACnetSegmentation	R	R
Max_Segments_Accepted	Unsigned	O ₁	-/R
VT_Classes_Supported	List of BACnetVTClass	O ₂	-
Active_VT_Sessions	List of BACnetVTSession	O ₂	-
Local_Time*	Time	O _{3,4}	R
Local_Date*	Date	O _{3,4}	R
UTC_Offset	INTEGER	O ₄	R
Daylight_Savings_Status	BOOLEAN	O ₄	R
APDU_Segment_Timeout	Unsigned	O ₁	-/R
APDU_Timeout	Unsigned	R	R
Number_Of_APDU_Retries	Unsigned	R	R
List_Of_Session_Keys	List of BACnetSessionKey	O	-
Time_Synchronization_Recipients	List of BACnetRecipient	O ₅	-/R
Max_Master	Unsigned(1..127)	O ₆	-/R
Max_Info_Frames	Unsigned	O ₆	-/R
Device_Address_Binding	List of BACnetAddressBinding	R	R
Database_Revision	Unsigned	R	R
Configuration_Files	BACnetARRAY[N] of BACnetObjectIdentifier	O ₇	-
Last_Restore_Time	BACnetTimeStamp	O ₇	-
Backup_Failure_Timeout	Unsigned16	O ₈	-
Active_COV_Subscriptions	List of BACnetCOVSubscription	O ₉	-/R
Slave_Proxy_Enable	BACnetARRAY[N] of BOOLEAN	O ₁₀	-/R
Manual_Slave_Address_Binding	List of BACnetAddressBinding	O ₁₀	-/R
Auto_Slave_Discovery	BACnetARRAY[N] of BOOLEAN	O ₁₁	-/R
Slave_Address_Binding	List of BACnetAddressBinding	O ₁₂	-/R
Last_Restart_Reason	BACnetRestartReason	O ₁₃	-
Time_Of_Device_Restart	BACnetTimeStamp	O ₁₃	-
Restart_Notification_Recipients	List of BACnetRecipient	O ₁₃	-
UTC_Time_Synchronization_Recipients	List of BACnetRecipient	O ₅	-/R
Time_Synchronization_Interval	Unsigned	O ₁₄	-/R
Align_Intervals	BOOLEAN	O ₁₄	-

Interval_Offset	Unsigned	O	-
Profile_Name	CharacterString		-

¹ Required if segmentation of any kind is supported.

² If one of the properties VT_Classes_Supported or Active_VT_Sessions is present, then both of these properties shall be present. Both properties are required if support for VT Services is indicated in the PICS.

³ If the device supports the execution of the TimeSynchronization service, then these properties shall be present.

⁴ If the device supports the execution of the UTCTimeSynchronization service, then these properties shall be present.

⁵ If this property is present, then Time_Synchronization_Interval, Align_Intervals and Interval_Offset shall be present. If present, this property shall be writable.

⁶ These properties are required if the device is an MS/TP master node.

⁷ These properties are required if the device supports the backup and restore procedures.

⁸ This property must be present and writable if the device supports the backup and restore procedures.

⁹ This property is required if the device supports execution of either the SubscribeCOV or SubscribeCOVProperty service.

¹⁰ This property shall be present and writable if the device is capable of being a Slave-Proxy device.

¹¹ This property shall be present if the device is capable of being a Slave-Proxy device that implements automatic discovery of slaves.

¹² This property shall be present if the device is capable of being a Slave-Proxy device.

¹³ These properties are required if the device supports the restart procedure as described in Clause 19.3.

¹⁴ If either Time_Synchronization_Recipients or UTC_Time_Synchronization_Recipients is present, then this property shall be present and writable.

Event Enrollment

Property Identifier	Property Datatype	Conf. Code	UGW-compact
Object_Identifier	BACnetObjectIdentifier	R	R
Object_Name	CharacterString	R	R
Object_Type	BACnetObjectType	R	R
Description	CharacterString	O	-/R/W
Event_Type	BACnetEventType	R	R
Notify_Type	BACnetNotifyType	R	R/W
Event_Parameters	BACnetEventParameter	R	R/W
Object_Property_Reference	BACnetDeviceObjectPropertyReference	R	R/W
Event_State	BACnetEventState	R	R
Event_Enable	BACnetEventTransitionBits	R	R/W
Acked_Transitions	BACnetEventTransitionBits	R	R
Notification_Class	Unsigned	R	R/W
Event_Time_Stamps	BACnetARRAY[3] of BACnetTimeStamp	R	R
Profile_Name	CharacterString	O	-/R/W

Each property can be set into its state (not present / required / writeable) according to the UGW compact code.

Multistate Input

Property Identifier	Property Datatype	Conf. Code	UGW-compact
Object_Identifier	BACnetObjectIdentifier	R	R
Object_Name	CharacterString	R	R
Object_Type	BACnetObjectType	R	R
Present_Value	Unsigned	R ₁	R/W
Description	CharacterString	O	-/R/W
Device_Type	CharacterString	O	-/R/W
Status_Flags	BACnetStatusFlags	R	R
Event_State	BACnetEventState	R	R
Reliability	BACnetReliability	O ₂	-/R/W
Out_Of_Service	BOOLEAN	R	R/W
Number_Of_States	Unsigned	R	R/W
State_Text	BACnetARRAY[N]of CharacterString	O	-/R/W
Time_Delay	Unsigned	O ₃	-/R/W
Notification_Class	Unsigned	O ₃	-/R/W
Alarm_Values	List of Unsigned	O ₃	-/R/W
Fault_Values	List of Unsigned	O ₃	-/R/W
Event_Enable	BACnetEventTransitionBits	O ₃	-/R/W
Acked_Transitions	BACnetEventTransitionBits	O ₃	-/R
Notify_Type	BACnetNotifyType	O ₃	-/R/W
Event_Time_Stamps	BACnetARRAY[3] of BACnetTimeStamp	O ₃	-/R
Profile_Name	CharacterString	O	-/R/W

¹ This property is required to be writable when Out_Of_Service is TRUE.

² This property shall be required if Fault_Values is present.

³ These properties are required if the object supports intrinsic reporting.

Each property can be set into its state (not present / required / writeable) according to the UGW compact code.

Multistate Output

Property Identifier	Property Datatype	Conf. Code	UGW-compact
Object_Identifier	BACnetObjectIdentifier	R	R
Object_Name	CharacterString	R	R
Object_Type	BACnetObjectType	R	R
Present_Value	Unsigned	W	W
Description	CharacterString	O	-/R/W
Device_Type	CharacterString	O	-/R/W
Status_Flags	BACnetStatusFlags	R	R
Event_State	BACnetEventState	R	R
Reliability	BACnetReliability	O	-/R/W
Out_Of_Service	BOOLEAN	R	R/W
Number_Of_States	Unsigned	R	R/W
State_Text	BACnetARRAY[N]of CharacterString	O	-/R/W
Priority_Array	BACnetPriorityArray	R	R
Relinquish_Default	Unsigned	R	R/W
Time_Delay	Unsigned	O ₁	-/R/W
Notification_Class	Unsigned	O ₁	-/R/W
Feedback_Value	Unsigned	O ₁	-/R/W
Event_Enable	BACnetEventTransitionBits	O ₁	-/R/W
Acked_Transitions	BACnetEventTransitionBits	O ₁	-/R
Notify_Type	BACnetNotifyType	O ₁	-/R/W
Event_Time_Stamps	BACnetARRAY[3] of BACnetTimeStamp	O ₁	-/R
Profile_Name	CharacterString	O	-/R/W

¹ These properties are required if the object supports intrinsic reporting.

Each property can be set into its state (not present / required / writeable) according to the UGW compact code.

Notification Class

Property Identifier	Property Datatype	Conf. Code	UGW-compact
Object_Identifier	BACnetObjectIdentifier	R	R
Object_Name	CharacterString	R	R
Object_Type	BACnetObjectType	R	R
Description	CharacterString	O	-/R/W
Notification_Class	Unsigned	R	R/W
Priority	BACnetARRAY[3] of Unsigned	R	R/W
Ack_Required	BACnetEventTransitionBits	R	R/W
Recipient_List	List of BACnetDestination	R	R/W
Profile_Name	CharacterString	O	-/R/W

Each property can be set into its state (not present / required / writeable) according to the UGW compact code.

Schedule

Property Identifier	Property Datatype	Conf. Code	UGW-compact
Object_Identifier	BACnetObjectIdentifier	R	R
Object_Name	CharacterString	R	R
Object_Type	BACnetObjectType	R	R
Present_Value	Any	R	R/W
Description	CharacterString	O	-/R/W
Effective_Period	BACnetDateRange	R	R/W
Weekly_Schedule	BACnetARRAY[7]of BACnetDailySchedule	O ₁	-/R/W
Exception_Schedule	BACnetARRAY[N]of BACnetSpecialEvent	O ₁	-/R/W
Schedule_Default	Any	R	R/W
List_Of_Object_Property_References	List of BACnetDeviceObjectPropertyReference	R	R/W
Priority_For_Writing	Unsigned(1..16)	R	R/W
Status_Flags	BACnetStatusFlags	R	R
Reliability	BACnetReliability	R	R/W
Out_Of_Service	BOOLEAN	R	R/W
Profile_Name	CharacterString	O	-/R/W

¹ At least one of these properties is required.

Each property can be set into its state (not present / required / writeable) according to the UGW compact code.

Multistate Value

Property Identifier	Property Datatype	Conf. Code	UGW-compact
Object_Identifier	BACnetObjectIdentifier	R	R
Object_Name	CharacterString	R	R
Object_Type	BACnetObjectType	R	R
Present_Value	Unsigned	R ₁	R/W
Description	CharacterString	O	-/R/W
Status_Flags	BACnetStatusFlags	R	R
Event_State	BACnetEventState	R	R
Reliability	BACnetReliability	O ₂	-/R/W
Out_Of_Service	BOOLEAN	R	R/W
Number_Of_States	Unsigned	R	R/W
State_Text	BACnetARRAY[N] of CharacterString	O	-/R/W
Priority_Array	BACnetPriorityArray	O ₃	-/R/W
Relinquish_Default	Unsigned	O ₃	-/R/W
Time_Delay	Unsigned	O ₄	-/R/W
Notification_Class	Unsigned	O ₄	-/R/W
Alarm_Values	List of Unsigned	O ₄	-/R/W
Fault_Values	List of Unsigned	O ₄	-/R/W
Event_Enable	BACnetEventTransitionBits	O ₄	-/R/W
Acked_Transitions	BACnetEventTransitionBits	O ₄	-/R
Notify_Type	BACnetNotifyType	O ₄	-/R/W
Event_Time_Stamps	BACnetARRAY[3] of BACnetTimeStamp	O ₄	-/R
Profile_Name	CharacterString	O	-/R/W

¹ If Present_Value is commandable, then it is required to also be writable. This property is required to be writable when Out_Of_Service is TRUE.

² This property shall be required if Fault_Values is present.

³ If Present_Value is commandable, then both of these properties shall be present.

⁴ These properties are required if the object supports intrinsic reporting.

Each property can be set into its state (not present / required / writeable) according to the UGW compact code.